

# KALISPELL FIRE DEPARTMENT

Dave Dedman – Fire Chief  
Jon Campbell – Assistant Fire Chief  
Cec Lee – Executive Secretary



PO Box 1997  
312 First Avenue East  
Kalispell, Montana 59901  
Phone: (406) 758-7760  
FAX: (406) 758-7777

## RECALL NOTICE

Kidde Recalls Dual Sensor Smoke Alarms Due to Risk of Failure to Alert Consumers to a Fire



Recalled Kidde dual sensor smoke alarm

**Name of product:**

Kidde dual-sensor (photoelectric and ionization) smoke alarms – models PI2010 and PI9010

**Hazard:**

A yellow cap left on during the manufacturing process can cover one of the two smoke sensors and compromise the smoke alarm's ability to detect smoke, posing a risk of consumers not being alerted to a fire in their home.

**Remedy:**

Replace

**Recall date:**

March 21, 2018

**Units:**

About 452,000 in the U.S. (In addition, about 40,000 were sold in Canada.)



**Consumer Contact:**

Kidde toll-free at 833-551-7739 from 8:30 a.m. to 5 p.m. ET Monday through Friday, from 9 a.m. to 3 p.m. on Saturday and Sunday, or online at [www.kidde.com](http://www.kidde.com) and click on "Product Safety Recall" for more information.

For more information please visit [WWW.KIDDE.COM](http://WWW.KIDDE.COM) or [CPSC RECALLS](#)

Date of issue: 3/22/2018

*"Protecting our community with the highest level of professionalism."*